

VILLAGE DISTRICT OF EASTMAN  
GLENWOOD WELLFIELD INTERCONNECTION  
ADDENDUM #1

THIS ADDENDUM #1 SHALL BECOME A PART OF THE BIDDING DOCUMENTS FOR THE GLENWOOD WELLFIELD INTERCONNECTION PROJECT. BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM #1 ON PAGE 10 OF 15 OF THEIR BID.

1. THE FOOTER IN SPECIFICATION SECTION 26 00 00 ELECTRICAL WORK SHALL BE REVISED TO STATE "VILLAGE DISTRICT OF EASTMAN, GLENWOOD WELLFIELD INTERCONNECTION, PROJECT #221211".
2. BID ITEM NO. 3 – TRANSMISSION MAIN: INCLUDES THE REQUIREMENT TO INSTALL APPROXIMATELY 560 FEET OF TRANSMISSION MAIN BY TRENCHLESS MEANS AND METHODS (UNDER WETLANDS). FOR THIS SECTION OF PIPING ONLY, THE BIDDER IS TO ASSUME THAT DRILLING WILL BE IN EARTH, AND NOT ROCK. IF ROCK IS ENCOUNTERED DURING DRILLING, ANY ADDITIONAL COSTS INCURRED WILL BE ADDRESSED VIA CHANGE ORDER AS EXTRA WORK.
3. THE INTENT FOR THE NEW ELECTRICAL SERVICE TO THE PUMP STATION IS TO INSTALL A SECONDARY SERVICE FROM THE EXISTING POLE ON GLENWOOD ROAD TO THE PUMP STATION ALONG THE EXISTING GRAVEL ACCESS DRIVE. THREE PULL BOXES ARE IDENTIFIED. WIRE SIZING FOR THE SERVICE IS TO BE COMPLETED BY THE LICENSED ELECTRICAL SUBCONTRACTOR. IF CHANGE(S) TO THE INTENT ARE REQUIRED BY THE LOCAL UTILITY PROVIDER, ANY INCREASED COSTS RESULTING FROM THE CHANGE(S) WILL BE ADDRESSED VIA CHANGE ORDER AS EXTRA WORK.
4. IF A BUILDING PERMIT IS REQUIRED, THE OWNER AND ENGINEER WILL ASSIST THE CONTRACTOR AS NEEDED TO OBTAIN THE PERMIT. THE OWNER WILL PAY THE COST OF THE BUILDING PERMIT IF ONE IS REQUIRED.

END OF ADDENDUM #1